

Annexure-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 17-08-2026

It is certified that an inspection team headed by

Pranay Dhyani (A.A.E.) (Name of Officers with designation)

from Uttarakhand Jal Sansthan Vikasnagar PHED

inspected the TIMES WORLD SCHOOL, WARD NO. 4, CANAL BYPASS ROAD, VIKASNAGAR

(Name & Address of the school) on 30-07-2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. 161/UJS/SDLW@TML/2026-27
dated 31.7.2026 of SDLW@TML, UJS, Vikasnagar (PHED Lab)

certified that the

TIMES WORLD SCHOOL, Vikasnagar (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year

Authorized Signatory

Signature with Seal: SDLW@TML, UJS, Vikasnagar

Name : Pranay Dhyani

Designation : A.A.E.

Name & Address of the Office / Department :

To
TIMES WORLD SCHOOL
WARD NO. 4, CANAL BYPASS ROAD, VIKASNAGAR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



उत्तराखण्ड जल संस्थान

3707

उ०ज०स०इ०

दिनांक 30/7/2026 370693

g Laboratory

: 31/07/2026

मौग पंजिका सं०..... बिल की अवधि..... बिल वितरण की तिथि.....

श्री. श्रीमती Times world school vikasnagar

भवन संख्या..... मोहल्ला मार्ग ग्राम.....से

जल मूल्य	मीटर किराया	जल संयोजक	जल कर	सीवर कर	सीवर शीट शुल्क	अवरचार्ज सीवर चार्ज	अन्य प्राप्ति	योग
water Testing payment							1040	1040

बिल सं०..... दिनांक..... के पूर्व/आंशिक

भुगतान के रूप में धनराशि अंको में 4040/- शब्दों में प्राप्ति हुई।

बिल राशि सं०..... रिबेट राशि सं०.....

लेखाधिकारी

ह० लिपिक

ple collected from

School

Analysis:30/07/2026

Analysis:31/07/2026

Std. Test Method

SN	Water Quality Parameters	Chemical Scope	Limit (BIS)	Limit (BIS) in the Absence of alternative source	
1.	pH	6.00	6.5 to 8.5	No Relaxation	IS 3025 Pt-11, 2022
2.	Total Dissolved Solids (TDS), mg/L	94	500	2000	IS 3025 Pt-16-2023
3.	Turbidity, NTU	1.57	1	5	IS 3025 Pt-10-2023
4.	Total Alkalinity (as CaCO ₃), mg/L	70	200	600	IS 3025 Pt-23: 2023
5.	Total Hardness (as CaCO ₃), mg/L	68	200	600	IS 3025 Pt-21: 2009 Ra,2019
6.	Chloride, mg/l	10	250	1000	IS 3025 Pt-32 : 2025
7.	Calcium (as Ca), mg/L	21.6	75	200	IS 3025 Pt-40 : 2023
8.	Magnesium (as Mg), mg/L	3.40	30	100	APHA 23rd Ed.-3500-Mg B: 2023
9.	Colour, Hazen	01	5	15	IS 3025 Pt-04 : 2021
10.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 Pt-05 : 2022
11.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 Pt-08 : 2012

(Er. J.S. Chauhan)

Quality Manager
SDWQTM, LAB

Uttarakhand Jal Sansthan
Vikasnagar

-End of Report-

- The results listed refer only to tested sample and applicable parameters.
- This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
- The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.



Scanned with OKEN Scanner



Sub Divisional Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Vikasnagar.
Ph (O): 9258186962, E-mail: jalkallab@gmail.com

Report ID: 161/UJS/SDLWQTML/2026-27

Dated: 31/07/2026

WATER QUALITY TEST REPORT

Name and Address of Organization/ Customer		Times World School Vikasnagar			
Product Description (Surface Water/ Ground Water/ Drinking Water)		Ground Water	Sample Description	One Water Sample Collected From Times World School	
Reference Sample Identification:		SDLWQTML/UJS/2026-27-161		Date of Start of Analysis: 30/07/2026	
				Date of End of Analysis: 31/07/2026	
Date and Time of Sample Received: 30/07/26 & 01:05 PM			Sample Collected by:	Beenu Dass	
SN	Water Quality Parameters Under Chemical Scope	Results	Desirable Limit (BIS)	Permissible Limit (BIS) in the Absence of alternative source	Std. Test Method
1	Total Coliform/100ml	Absent	Absent	Absent	IS 15185:2016 Ref 2021
2	E.Coli/100ml	Absent	Absent	Absent	IS 15185:2016 Ref 2021
3	Residual Free Chlorine, mg/L	0.0	0.2	1.0	IS 3025 Pt-26:1986

(Er. J.S. Chauhan)

Quality Manager
SDWQTM, LAB
Uttarakhand Jal Sansthan
Vikasnagar

-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts for promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.

